



Building Permit & Inspection Records

Building Permit and Inspection Records

Disclaimer

The information presented on this website is informational only and does not necessarily reflect the current condition of the building or property. The fact that a permit was issued does not confirm that work was performed, or that work was performed in accordance with that permit and the requirements of the Municipal Code.

Information on inspections and alleged violations reflect conditions found by the inspector at the time of the inspection and not necessarily the current status of those alleged violations or the current condition of the property. The absence of alleged violations on this website does not mean a building or property is in compliance with the requirements of the Municipal Code.

The Department of Buildings may refer certain alleged violations to the City's Department of Law for enforcement proceedings in the Department of Administrative Hearings or the Circuit Court of Cook County. Please contact the [Department of Administrative Hearings](#) or the [Clerk of the Circuit Court](#), respectively to obtain records of these proceedings.

ADDRESS: 2241 S HALSTED ST

Search within these results:

Inspection # 13175017

VIOLATIONS	BUILDING CODE CITATION	VIOLATION DETAILS

EV1110	Failed to maintain electric elevator equipment provided at premises in safe and sound working condition. (13-196-590, 13-196-630(b), 18-30-001)	Provide the safety edge for freight doors and remove the metal overlap hazard
EV1110	Failed to maintain electric elevator equipment provided at premises in safe and sound working condition. (13-196-590, 13-196-630(b), 18-30-001)	Provide the pull straps for all doors and gate
EV1110	Failed to maintain electric elevator equipment provided at premises in safe and sound working condition. (13-196-590, 13-196-630(b), 18-30-001)	Provide Capacity plate, "No Passenger" signage, Emerg bell inside freight
EV1110	Failed to maintain electric elevator equipment provided at premises in safe and sound working condition. (13-196-590, 13-196-630(b), 18-30-001)	Provide a pit stop switch freight
EV1110	Failed to maintain electric elevator equipment provided at premises in safe and sound working condition. (13-196-590, 13-196-630(b), 18-30-001)	Properly decommission freight #2303
EV1110	Failed to maintain electric elevator equipment provided at premises in safe and sound working condition. (13-196-590, 13-196-630(b), 18-30-001)	Provide a guarded light and guard for starter located near the entrance, to prevent Electrical hazard
EV1110	Failed to maintain electric elevator equipment provided at premises in safe and sound working condition. (13-196-590, 13-196-630(b), 18-30-001)	Provide at least one GFCI inside machine room
EV1110	Failed to maintain electric elevator	Provide an ABC fire ext in machine

	equipment provided at premises in safe and sound working condition. (13-196-590, 13-196-630(b), 18-30-001)	room
EV1110	Failed to maintain electric elevator equipment provided at premises in safe and sound working condition. (13-196-590, 13-196-630(b), 18-30-001)	Provide a lockable disconnect freight

Showing 1 to 9 of 9 entries

[Home](#) : [Disclaimer](#) : [Privacy Policy](#) : [Web Standards](#) : [Site Credits](#) : [Site Map](#) : [Contact Us](#) : [Press Room](#)

Copyright © 2018 - 2023 City of Chicago